


# Termination Board

## HiCTB16-YRS-RRB-AK-CC-DO16




- System board for Yokogawa ProSafe-RS
- For 16-channel DO card SDV541
- For 16 modules
- Recommended modules: HiC2871 (DO), HiC2873 (DO), HiC2877 (DO)
- 24 V DC supply
- Hazardous area: spring terminals, blue
- Non-hazardous area: Yokogawa system connector, 50-pin



### Function

The function of the termination board and the connector pin assignment is exactly fitted to the requirements of the Yokogawa ProSafe-RS system. The signal is output to the safety instrumented system via the system connector. Information about a missing supply voltage of the isolators is available for the system as a volt-free contact. The termination board has a robust plastic housing. The termination board is mounted in the switch cabinet on a 35 mm DIN mounting rail according to EN 60175.

### Connection



### Technical Data

| Supply                      |  |
|-----------------------------|--|
| Connection                  | X20: terminals 3, 5(+); 4, 6(-)  |
| Nominal voltage             | 24 V DC , in consideration of rated voltage of used isolators                            |
| Voltage drop                | 0.9 V , voltage drop across the series diode on the termination board must be considered |
| Ripple                      | ≤ 10 %   |
| Fusing                      | 4 A , in each case for 16 modules  |
| Power dissipation           | ≤ 500 mW , without modules   |
| Reverse polarity protection | yes  |
| Redundancy                  |  |
| Supply                      | Redundancy available. The supply for the isolators is decoupled, monitored and fused.    |
| Fault indication output     |  |

Release date: 2022-08-31 | Date of issue: 2022-08-31 | Filename: 236184\_eng.pdf

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Pepperl+Fuchs Group  
www.pepperl-fuchs.com

USA: +1 330 486 0002  
pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222  
pa-info@de.pepperl-fuchs.com


Singapore: +65 6779 9091  
pa-info@sg.pepperl-fuchs.com

**PEPPERL+FUCHS**

## Technical Data


|  |   |
|--|---|
| Connection   | X20: terminals 1, 2   |
| Output type  | volt-free contact   |
| Switch behaviour   | no fault: relay contact closed<br>power supply fault: relay contact open  |
| Contact loading  | 30 V DC , 1 A   |
| <b>Indicators/settings</b>                                     |   |
| Display elements   | LEDs PWR ON (Termination Board power supply)<br>- LED power supply I, green LED<br>- LED power supply II, green LED<br>LED FAULT (fault indication), red LED<br>- LED flashes: power supply fault |
| <b>Directive conformity</b>                                    |   |
| Electromagnetic compatibility                                  |   |
| Directive 2014/30/EU   | EN 61326-1:2013 (industrial locations)  |
| <b>Conformity</b>  |   |
| Electromagnetic compatibility                                  | NE 21:2017<br>For further information see system description.   |
| Degree of protection   | IEC 60529:2001  |
| <b>Ambient conditions</b>                                      |   |
| Ambient temperature  | -20 ... 60 °C (-4 ... 140 °F)   |
| Storage temperature  | -40 ... 70 °C (-40 ... 158 °F)  |
| <b>Mechanical specifications</b>                               |   |
| Degree of protection   | IP20  |
| Connection   |   |
| Field side   | explosion hazardous area: spring terminals , blue   |
| Control side   | non-explosion hazardous area: Yokogawa system connector, 50-pin   |
| Supply   | pluggable screw terminals , black   |
| Fault output   | pluggable screw terminals , black   |
| Core cross section   | spring terminals:<br>rigid: 0.2 ... 2.5 mm <sup>2</sup><br>flexible: 0.25 ... 1.5 mm <sup>2</sup>   |
| Material   | housing: polycarbonate  |
| Mass   | approx. 630 g   |
| Dimensions   | 240 x 175 x 153 mm (9.45 x 6.9 x 6.02 inch) (W x H x D) , depth including module assembly   |
| Mounting   | on 35 mm DIN mounting rail acc. to EN 60715:2001  |
| <b>Data for application in connection with hazardous areas</b> |   |
| EU-type examination certificate                                | CESI 06 ATEX 022  |
| Marking  | ⊕ II (1)G [Ex ia Ga] IIC<br>⊕ II (1)D [Ex ia Da] IIIC<br>⊕ I (M1) [Ex ia Ma] I  |
| Non-hazardous area   |   |
| Maximum safe voltage   | 250 V (Attention! U <sub>m</sub> is no rated voltage.)  |
| Galvanic isolation   |   |
| Field circuit/control circuit                                  | safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V   |
| Directive conformity   |   |
| Directive 2014/34/EU   | EN IEC 60079-0:2018+AC:2020 , EN 60079-11:2012 , EN 50303:2000  |
| <b>International approvals</b>                                 |   |
| IECEx approval   |   |
| IECEx certificate  | IECEx CES 06.0003   |
| IECEx marking  | [Ex ia Ga] IIC<br>[Ex ia Da] IIIC<br>[Ex ia Ma] I   |
| <b>General information</b>                                     |   |
| Supplementary information                                      | Observe the certificates, declarations of conformity, instruction manuals, and manuals where applicable. For information see <a href="http://www.pepperl-fuchs.com">www.pepperl-fuchs.com</a> .   |

**Accessories**

|   |                            |  |
|---|----------------------------|--|
|  | <b>HiALC-HICTB-SET-108</b> | Label carrier for HiC termination boards |
|---|----------------------------|--|

**Application**

**Typical circuit**



**Module switch settings**

| Type (DO)  | DIP switch    | Position |
|--|---------------|----------|
| HiC2871  | not available |          |
| HiC2873, HiC2877<br><ul style="list-style-type: none"> <li>Loop powered</li> <li>Control input: without function</li> <li>Line fault detection: disabled</li> <li>Filter: enabled</li> </ul> | S1            | OFF      |
|  | S2            | ON       |
|  | S3            | ON       |
|  | S4            | ON       |
|  | S5            | OFF      |
|  | S6            | ON       |
|  | S7            | OFF      |
|  | S8            | OFF      |



For exact pin assignment for connection to field side and control side, see the documentation of the isolated barrier.



The pin-out configuration has to be observed. For information see corresponding pin-out table on [www.pepperl-fuchs.com](http://www.pepperl-fuchs.com).

Release date: 2022-08-31 Date of issue: 2022-08-31 Filename: 236184\_eng.pdf